

**Annexure C**

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION**

**CERTIFICATE**




No. PHEE/KOR-I/Ws-133(G)/2025-26/ **683**

Date : **30/06/2025**

It is certified that an inspection team headed by Miss Haina Brahma, Nodal Officer cum Lab I/c, DLL Kokrajhar from Public Health Engineering Department, Kokrajhar inspected the Brahma Baba Techno School, Kokrajhar Vill-janagaon, Kokrajhar BTR Assam on 25/06/2025 and on the basis of Water Test Report (Attached) ULR No TC14819 25000000220F & DLLKOK2025MBL0053 dated 30/06/2025 of District Level Laboratory Kokrajhar certified that the Brahma Baba Techno School, Kokrajhar has safe drinking water facilities for the students and members of staff of the institution and observed during the inspection that the authority is maintaining the hygienic sanitation condition in the school building & the campus of the institution.

The above is valid for a period of 6 Months from the date of issue,.

Signature with Seal :

  
Executive Engineer (PHE)  
Kokrajhar, Division No. I  
Kokrajhar

Name : Er. Hitesh Rabha

Designation : Executive Engineer (PHE)

Address: O/o The Executive Engineer (PHE)  
Kokrajhar Division No. I Kokrajhar

To

The Principal  
Brahma Baba Techno School,  
Kokrajhar





TC-14819

**DISTRICT LEVEL LABORATORY KOKRAJHAR**  
**OFFICE OF THE EXECUTIVE ENGINEER (PHE), KOKRAJHAR DIVISION NO. I**  
**KOKRAJHAR, ASSAM PIN - 783370**  
**Email id: [dllkokrajhar@gmail.com](mailto:dllkokrajhar@gmail.com)**

**TEST REPORT**

ULR NO	TC14819 25000000220F		
Source Type	Filter		
Village/Address	Janagaon	Block	Kokrajhar
Pin Point Location	Brahma Baba Techno School Kokrajhar	Contact No	
Sample Description:	Drinking water	Report Issue Date:	30/06/2025
Test Start Date:	25/06/2025	Date Of Receipt:	25/06/2025
Sample Condition	Good, Maintained at 4°C	Test End Date:	27/06/2025

Sample Collected By:	Sibasish Kar(DLL Staff)
Sample ID:	S30375135

Sr. No	Parameters	Methods	Units	Results	Acceptable Limits	Permissible limits
1	Colour	IS 3025 (Part 4)	Hazen units	<5	5	15
2	Odour	IS 3025 (Part 5)	-	Agreeable	Agreeable	Agreeable
3	pH at 25°C	IS 3025 (Part 11)	-	6.85	6.5 to 8.5	No relaxation
4	Taste	IS 3025 (Part 8)	-	Agreeable	Agreeable	Agreeable
5	Turbidity	IS 3025 (Part 10)	NTU	0.3	1	5
6	Total dissolved solids	IS 3025 (Part 16)	mg/L	110	500	2000
7	Total Hardness (as CaCO <sub>3</sub> )	IS 3025 (Part 21)	mg/L	66	200	600
8	Total Alkalinity (as CaCO <sub>3</sub> )	IS 3025 (Part 23)	mg/L	80	200	600
9	Chloride(as Cl)	IS 3025 (Part 32)	mg/L	28.99	250	1000
10	Calcium(as Ca)	IS 3025 (Part 40)	mg/L	21.73	75	200
11	Magnesium (as Mg)	APHA 24th EDITION -3500-Mg Method B (By Calculation)	mg/L	2.86	30	100
12	Nitrate(as NO <sub>3</sub> )	IS 3025 (Part 34)	mg/L	1.14	45	No relaxation
13	Iron(as Fe)	APHA 24th EDITION -3500-Fe Method B (Phenanthroline Method)	mg/L	BDL	1	No relaxation
14	Fluoride(as F)	APHA 24th EDITION -4500-F Method D (SPADNS Method)	mg/L	0.11	1	1.5
15	Arsenic(as As)	IS 3025 (Part 37)	mg/L	BDL	0.01	No relaxation
16	Sulphate	IS 3025 (Part 24)	mg/L	2.18	200	400

**Opinion:** The Parameters tested above meet the requirement of IS 10500:2012 (Second Revision).

**Note:**

- The test report and result relate to the sample as received and tested in the laboratory
- The test reports shall not be reproduced in whole or in parts, without the prior consent of the laboratory.
- The test report is not intended for any publicity or any legal purposes.
- Any correction invalidates this test reports.
- The test sample meant for chemical analysis will be disposed of after 15 days from the date of issue of test report unless specified by customer for retaining over a longer period.
- BDL for arsenic (<0.009mg/l) , Iron (<0.1mg/l) , Fluoride (<0.1mg/l) , Nitrate (<0.2mg/l) , TDS (<5mg/l)

Tested by  
(Dasharat Brahma)

LAB/QF-7.8  
\_ END OF REPORT \_

Authorized By  
(Haina Brahma)